

§ 141.43

In addition, States may require identification and reporting of other materials of construction present in distribution systems that may contribute contaminants to the drinking water, such as:

Vinyl lined asbestos cement pipe.
Coal tar lined pipes and tanks.

[45 FR 57346, Aug. 27, 1980; 47 FR 10999, Mar. 12, 1982, as amended at 59 FR 62470, Dec. 5, 1994]

§ 141.43 Prohibition on use of lead pipes, solder, and flux.

(a) *In general*—(1) *Prohibition*. Any pipe, solder, or flux, which is used after June 19, 1986, in the installation or repair of—

- (i) Any public water system, or
- (ii) Any plumbing in a residential or nonresidential facility providing water for human consumption which is connected to a public water system shall be lead free as defined by paragraph (d) of this section. This paragraph (a)(1) shall not apply to leaded joints necessary for the repair of cast iron pipes.

(2) [Reserved]

(b) *State enforcement*—(1) *Enforcement of prohibition*. The requirements of paragraph (a)(1) of this section shall be enforced in all States effective June 19, 1988. States shall enforce such requirements through State or local plumbing codes, or such other means of enforcement as the State may determine to be appropriate.

(2) [Reserved]

(c) *Penalties*. If the Administrator determines that a State is not enforcing the requirements of paragraph (a) of this section, as required pursuant to paragraph (b) of this section, the Administrator may withhold up to 5 percent of Federal funds available to that State for State program grants under section 1443(a) of the Act.

(d) *Definition of lead free*. For purposes of this section, the term lead free:

- (1) When used with respect to solders and flux refers to solders and flux containing not more than 0.2 percent lead;
- (2) When used with respect to pipes and pipe fittings refers to pipes and pipe fittings containing not more than 8.0 percent lead; and
- (3) When used with respect to plumbing fittings and fixtures intended by

40 CFR Ch. I (7–1–13 Edition)

the manufacturer to dispense water for human ingestion refers to fittings and fixtures that are in compliance with standards established in accordance with 42 U.S.C. 300g–6(e).

[52 FR 20674, June 2, 1987, as amended at 65 FR 2003, Jan. 12, 2000]

Subpart F—Maximum Contaminant Level Goals and Maximum Residual Disinfectant Level Goals

§ 141.50 Maximum contaminant level goals for organic contaminants.

(a) MCLGs are zero for the following contaminants:

- (1) Benzene
- (2) Vinyl chloride
- (3) Carbon tetrachloride
- (4) 1,2-dichloroethane
- (5) Trichloroethylene
- (6) Acrylamide
- (7) Alachlor
- (8) Chlordane
- (9) Dibromochloropropane
- (10) 1,2-Dichloropropane
- (11) Epichlorohydrin
- (12) Ethylene dibromide
- (13) Heptachlor
- (14) Heptachlor epoxide
- (15) Pentachlorophenol
- (16) Polychlorinated biphenyls (PCBs)
- (17) Tetrachloroethylene
- (18) Toxaphene
- (19) Benzo[a]pyrene
- (20) Dichloromethane (methylene chloride)
- (21) Di(2-ethylhexyl)phthalate
- (22) Hexachlorobenzene
- (23) 2,3,7,8-TCDD (Dioxin)

(b) MCLGs for the following contaminants are as indicated:

Contaminant	MCLG in mg/l
(1) 1,1-Dichloroethylene	0.007
(2) 1,1,1-Trichloroethane	0.20
(3) para-Dichlorobenzene	0.075
(4) Aldicarb	0.001
(5) Aldicarb sulfoxide	0.001
(6) Aldicarb sulfone	0.001
(7) Atrazine	0.003
(8) Carbofuran	0.04
(9) o-Dichlorobenzene	0.6
(10) cis-1,2-Dichloroethylene	0.07
(11) trans-1,2-Dichloroethylene	0.1
(12) 2,4-D	0.07
(13) Ethylbenzene	0.7
(14) Lindane	0.0002
(15) Methoxychlor	0.04

Environmental Protection Agency

§ 141.55

Contaminant	MCLG in mg/l
(16) Monochlorobenzene	0.1
(17) Styrene	0.1
(18) Toluene	1
(19) 2,4,5-TP	0.05
(20) Xylenes (total)	10
(21) Dalapon	0.2
(22) Di(2-ethylhexyl)adipate4
(23) Dinoseb007
(24) Diquat02
(25) Endothall1
(26) Endrin002
(27) Glyphosate7
(28) Hexachlorocyclopentadiene05
(29) Oxamyl (Vydate)2
(30) Picloram5
(31) Simazine004
(32) 1,2,4-Trichlorobenzene07
(33) 1,1,2-Trichloroethane003

[50 FR 46901, Nov. 13, 1985, as amended at 52 FR 20674, June 2, 1987; 52 FR 25716, July 8, 1987; 56 FR 3592, Jan. 30, 1991; 56 FR 30280, July 1, 1991; 57 FR 31846, July 17, 1992]

§ 141.51 Maximum contaminant level goals for inorganic contaminants.

(a) [Reserved]

(b) MCLGs for the following contaminants are as indicated:

Contaminant	MCLG (mg/l)
Antimony	0.006
Arsenic	zero ¹
Asbestos	7 Million fibers/liter (longer than 10 µm).
Barium	2
Beryllium004
Cadmium	0.005
Chromium	0.1
Copper	1.3
Cyanide (as free Cyanide)2
Fluoride	4.0
Lead	zero
Mercury	0.002
Nitrate	10 (as Nitrogen).
Nitrite	1 (as Nitrogen).
Total Nitrate+Nitrite	10 (as Nitrogen).
Selenium	0.05
Thallium0005

¹ This value for arsenic is effective January 23, 2006. Until then, there is no MCLG.

[50 FR 47155, Nov. 14, 1985, as amended at 52 FR 20674, June 2, 1987; 56 FR 3593, Jan. 30, 1991; 56 FR 26548, June 7, 1991; 56 FR 30280, July 1, 1991; 57 FR 31846, July 17, 1992; 60 FR 33932, June 29, 1995; 66 FR 7063, Jan. 22, 2001]

§ 141.52 Maximum contaminant level goals for microbiological contaminants.

(a) MCLGs for the following contaminants are as indicated:

Contaminant	MCLG
(1) <i>Giardia lamblia</i>	zero

Contaminant	MCLG
(2) Viruses	zero
(3) <i>Legionella</i>	zero
(4) Total coliforms (including fecal)	zero
coliforms and <i>Escherichia coli</i> .	
(5) <i>Cryptosporidium</i>	zero
(6) <i>Escherichia coli</i> (<i>E. coli</i>)	zero

(b) The MCLG identified in paragraph (a)(4) of this section is applicable until March 31, 2016. The MCLG identified in paragraph (a)(6) of this section is applicable beginning April 1, 2016.

[78 FR 10347, Feb. 13, 2013]

§ 141.53 Maximum contaminant level goals for disinfection byproducts.

MCLGs for the following disinfection byproducts are as indicated:

Disinfection byproduct	MCLG (mg/L)
Bromodichloromethane	zero
Bromoform	zero
Bromate	zero
Chlorite	0.8
Chloroform	0.07
Dibromochloromethane	0.06
Dichloroacetic acid	zero
Monochloroacetic acid	0.07
Trichloroacetic acid	0.02

[63 FR 69465, Dec. 16, 1998, as amended at 65 FR 34405, May 30, 2000; 71 FR 478, Jan. 4, 2006]

§ 141.54 Maximum residual disinfectant level goals for disinfectants.

MRDLGs for disinfectants are as follows:

Disinfectant residual	MRDLG(mg/L)
Chlorine	4 (as Cl ₂).
Chloramines	4 (as Cl ₂).
Chlorine dioxide	0.8 (as ClO ₂)

[63 FR 69465, Dec. 16, 1998]

§ 141.55 Maximum contaminant level goals for radionuclides.

MCLGs for radionuclides are as indicated in the following table:

Contaminant	MCLG
1. Combined radium-226 and radium-228	Zero.
2. Gross alpha particle activity (excluding radon and uranium)	Zero.
3. Beta particle and photon radioactivity	Zero.
4. Uranium	Zero.

[65 FR 76748, Dec. 7, 2000]